

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
English Bazar Fire Station, Ghorapir, Maldah, Pin -
732101**

Memo No : IND/WB/FES/20192020/78786

DATE: 26/02/2020

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**Delhi World Public School Malda
Nityananda Pur, Mouza-Dilal Pur, J.L.No-87, Khatian No-39, Plot No-5,6, P.S-English
Bazar, Dist-Malda
English Bazar F.S., English Bazar,
Malda - 732128 .**

Sub :Fire Safety Certificate for the occupancy of an existing Ground floor construction of G + 3 storied building under group Educational at the premises no.- Nityananda Pur, Mouza-Dilal Pur, J.L.No-87, Khatian No-39, Plot No-5,6, P.S-English Bazar, Dist-Malda, Pin - 732128

This is in reference to your Application No. IND/WB/FES/20192020/78786, dated 26/02/2020, regarding the Fire Safety Certificate for the occupancy of an existing Ground floor construction of G + 3 storied building under group Educational at the premises no.- Nityananda Pur, Mouza-Dilal Pur, J.L.No-87, Khatian No-39, Plot No-5,6, P.S-English Bazar, Dist-Malda, Pin - 732128.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Good housekeeping to be maintained both inside as well as outside the building.
2. Floor Numbers as well as directional signs of escape routes to be prominently displayed.
3. Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building.
4. The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies.
5. Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
6. Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.
7. All Exit & Entrance should be free from obstruction.
8. Fire license to be obtained from Collector W.B.F&E.S, for the premises (if any) which attracts under Sec – 12 of the Fire Service Act. 1950
9. This certificate will be renewed after 3 (Three) Years from the date of issue. As per Govt. of West Bengal Vide Notification No-629_L Dated-17/04/2018.

Note: Any deviation and changes the nature of use of the building without obtaining prior permission of the respective department, it may be treated as cancel.

Divisional Fire Officer
West Bengal Fire & Emergency Services